



Přepočet nejčastěji používaných jednotek v chlazení

Veličina	Jednotka	Koeficient	Jednotka	Koeficient	Jednotka
Délka	in (palec)	x 25,4	= mm	x 0,003937	in (palec)
	ft (stopa)	x 0,3048	= m	x 3,2808	ft (stopa)
Plocha	in ²	x 625,16	= mm ²	x 0,00155	in ²
	ft ²	x 0,0929	= m ²	x 10,764	ft ²
Objem	in ³	x 16 387	= mm ³	x 0,000061	in ³
	ft ³	x 0,02832	= m ³	x 35,31	ft ³
	ft ³	x 28,32	= litr	x 0,0353	ft ³
	pints (pinta)	x 0,56825	= litr	x 1,7598	pints
	imp.gal.(UK gal)*	x 4,546	= litr	x 0,22	imp.gal
	US gal*	x 3,785	= litr	x 0,26	US gal.
Hmotnost	lbs(libra)	x 0,4536	= kg	x 2,2046	lbs
Síla	lbs	x 4,448	= N	x 0,22482	lbs
Rychlosť	ft/min	x 0,00508	= m/sec	x 196,85	ft/min
Průtok objemový	imp.gal/min	x 0,07577	= litr/sec	x 13,2	imp.gal/min
	imp.gal/hod	x 0,000125	= m ³ /sec	x 7936,51	imp.gal/min
	ft ³ /min	x 000472	= m ³ /sec	x 2118,64	ft ³ /min
Průtok hmotn.	lb/h	x 0,000126	= kg/sec	x 7936,51	lb/h
Tlak	lb/in ²	x 0,0689	= bar	x 14,50	lb/in ²
	lb/in ²	x 0,0703	= kg/cm ²	x 14,22	lb/in ²
	kg/cm ²	x 0,9807	= bar	x 1,02	kg/cm ²
Hustota	lb/in ³	x 16,0185	= kg/m ³	x 0,06243	lb/in ³
Tepelný výkon	Btu/h	x 0,2931	= W	x 3,4118	Btu/h
	Btu/h	x 0,0002931	= kW	x 3411,8	Btu/h
	TR (refrig.tons)	x 12 000	= Btu/h	x 0,000083	TR
	Btu/h	x 0,252	= kcal/h	x 3,968	Btu/h
	kcal/h	x 1,163	= W	x 0,8598	kcal/h
	kcal/h	x 0,001163	= kW	x 859,845	kcal/h
Měrný tepel. výkon	Btu/h ft ²	x 3,155	= W/m ²	x 0,31696	Btu/h ft ²
	kcal/h m ²	x 1,163	= W/m ²	x 0,8598	kcal/h m ²
	Btu/h ft ²	x 2,7128	= kcal/h m ²	x 0,3686	Btu/h ft ²
Tepelná vodivost	Btu/ft h °F	x 1,731	= W/m °C	x 0,5777	Btu/ft h °F
	kcal/h m ² °C	x 1,163	= W/m °C	x 0,8598	kcal/h m ² °C
	Btu/ft h °F	x 1,4884	= kcal/mh °C	x 0,67186	Btu/ft h °F
Součinitel	Btu/ft h °F	x 5,678	= W/m ² °C	x 0,176118	Btu/ft h °F
přestupu tepla	kcal/h m ² °C	x 1,163	= W/m ² °C	x 0,8598	kcal/h m ² °C
	Btu/ft h °F	x 4,8822	= kcal/h m ² °C	x 0,20482	Btu/ft h °F

Poznámka: * US gal = objem v USA UK gal = Imp.gal. = objem ve Velké británii